

**LAGRANGE COUNTY REGIONAL UTILITY DISTRICT  
CUSTOMER RECONNECTION  
PERMIT/CHECKLIST**

---

1. Obtain permit to connect from LCRUD located  
at 116 E Wayne Street, LaGrange, Indiana

Date issued: \_\_\_\_\_

Date scheduled: \_\_\_\_\_

2. 24 hour notice prior to inspection by calling  
260-351-2163 7:00 A.M.-3:00 P.M.  
Monday thru Friday \*No Weekend Inspections\*  
Call IUPPS (800-382-5544)

Connections from the grinder to the force main must be completed by a state licensed plumber

3. Inspection of gravity sewer line;

a) No clear water discharge to system

- \_\_\_\_\_ -sump pump
- \_\_\_\_\_ -downspout
- \_\_\_\_\_ -foundation drains
- \_\_\_\_\_ -heat pumps
- \_\_\_\_\_ -cooling water
- \_\_\_\_\_ -other

b) Proper pipe material

- \_\_\_\_\_ -SDR 21

c) Proper slope

- \_\_\_\_\_ -4" = 1/8" per ft.
- \_\_\_\_\_ -6" = 1/8" per ft.

d) Proper pipe bedding (4" min. under pipe & 6" min. over top of pipe)

- \_\_\_\_\_ -sand or >B= Borrow
- \_\_\_\_\_ -no large objects or rocks

e) No 90 degree bends

- \_\_\_\_\_ -6" minimum between 45 degree bends

f) Cleanouts/overflows

- \_\_\_\_\_ -at building foundations w/a goose neck (invert of goose neck to be below floor elevation)
- \_\_\_\_\_ -at every equivalent 90 degree turn ( no goose neck required, screw on cap)
- \_\_\_\_\_ -every 150ft. of sewer ( no goose neck required, screw on cap)
- \_\_\_\_\_ -cleanouts are a min. of 2" above ground
- \_\_\_\_\_ -check valve is optional on single pumps, but recommended
- \_\_\_\_\_ -check valve is mandatory for double pumps (located near home)

g) Internal lift pumps

- \_\_\_\_\_ -District approved pump
- \_\_\_\_\_ -unapproved pumps must be removed and/or replaced with approved District pump

**5. Existing grinder pump unit/pump # \_\_\_\_\_**

- \_\_\_\_\_ a) Inspect connection to 4" influent line or cleanout
- \_\_\_\_\_ b) Open ball valve on discharge line inside of grinder unit
- \_\_\_\_\_ c) Turn on breaker at grinder pump unit junction box, and check that power is on at breaker at meter at power pole

**Signed:** \_\_\_\_\_ **Date Inspected:** \_\_\_\_\_  
LaGrange County Regional Utility District Inspector

**Signed:** \_\_\_\_\_ **Date:** \_\_\_\_\_  
Homeowner

**Signed:** \_\_\_\_\_ **Date:** \_\_\_\_\_  
Agent

**Agent:** \_\_\_\_\_ **Date:** \_\_\_\_\_  
Print Name

**Comments:** \_\_\_\_\_

**Reinspection: Yes or No** **Date:** \_\_\_\_\_

Use the space above to show the general layout of the property, including house and buildings, new grinder pump unit, old septic tank and absorption field, and all drain lines where they go.